



NOTES

1. EMERGENCY BOOSTER/TANK BYPASS VALVE & NRV TO BE FITTED ON HORIZONTAL PIPE. VRV TO BE SWINGING CLACK TYPE 35mm.
2. ALL PUMPS TO BE FITTED WITH INTEGRAL VALVES.
3. ALL LOW POINTS TO BE FITTED WITH DRAIN COCKS.
4. HEATING FLOW, HWS PRIMARY & TOWEL RAIL OUTGOING FLOW PIPES TO BE FITTED WITH REGULATING VALVES.
5. 2No 70 LITRE EXPANSION/ACCUMULATOR VESSELS NOT SHOWN ON PLAN. ONE CONNECT TO HEATING FLOW. ONE CONNECT TO BOOSTER OUTLET PRIOR TO VALVES.
6. MEGAFLOW MANUFACTURERS INFORMATION TO BE STRICTLY COMPLIED WITH.