



- SMALL POWER LEGEND**
- 3 COMPARTMENT DADO TRUNKING
 - 13A TWIN SWITCHED SOCKET OUTLET
 - 13A SINGLE SWITCHED SOCKET OUTLET
 - 13A SPUR UNIT
- MAINS LEGEND**
- EXISTING RYFIELD CHAMBER TO BE RETAINED
 - EXISTING DISTRIBUTION BOARD TO BE REPLACED TO SUIT AREA
 - EXISTING LOCAL AUTHORITY CHECK METER
 - 13A SPUR UNIT FOR MECHANICAL WALL PANEL HEATER
 - PULL CORD TO CONTROL ELECTRIC SHOWER BY MECHANICAL CONTRACTOR
- DISABLED TOILET ALARM LEGEND**
- POWER SUPPLY UNIT
 - PULL CORD
 - RESET
 - REMOTE INDICATOR
- LIGHTING LEGEND**
- 600 x 600 CASCADE - 1 x 55W TC-L LOUVER
 - AS ABOVE C/W 3 HOUR EMERGENCY PACK
 - WHITECROFT MIRAGE 2 x 18W TC-D HF DOWNLIGHTER
 - AS ABOVE C/W 3 HOUR EMERGENCY PACK
 - WHITECROFT MIRAGE IP44 2 x 18W TC-D HF DOWNLIGHTER C/W OPAL POLYCARBONATE DIFFUSER
 - AS ABOVE C/W 3 HOUR EMERGENCY PACK
 - METWAY
 - WHITECROFT VESPERE 2 x 36W TC-L HF WALL LIGHT
 - AS ABOVE C/W 3 HOUR EMERGENCY PACK
 - NEW FLUORESCENT BATTEN FITTING WITHIN NEW DOOR FRAM. PLUG IN CEILING VOID FOR CONNECTING FITTINGS
 - ACCESS PANEL
 - 1500mm BATTEN FITTING
 - COMPACT FLUORESCENT
 - SURFACE DIRM
 - DETOTES EMERGENCY
 - PIR
 - METWAY MICROWAVE PRESENCE DETECTOR TIME OUT PERIOD 15 SECONDS TO 30 MINS DETECTION ZONE - 20M IN FRONT OF PIR
 - LIGHTING CONTROL MODULE
 - 3 GANG SWITCH - 2 x 1 WAY SWITCHES 1 x EMERGENCY LIGHTING TEST KEY SWITCH



NOTES:

- DOOR FRAME LIGHTING TO BE CONTROLLED BY A TIMELOCK LOCATED ADJACENT DBLGS/LL & DB-WALL IN EXISTING ELECTRICAL RISER.
- CORRIDOR LIGHTING CONTROLLED BY PIR DETECTION LIGHTS ARE SERVED BY NORTH & SOUTH LANDLORDS DISTRIBUTION BOARDS. PIR LOCATIONS PROVIDE CROSS OVER OF DETECTION ZONES.